

ENERGY AUDIT ACTION PLAN

SHORT TERM		COMPLETED /EXPLORED	DATE	COMMENTS
Heating Controls	Obtain quotes for installing a Smart Control System			Oct 24 - In the process of obtaining quotes.
Heating Controls	Obtain quotes for installing smart TRV's on each radiator			Oct 24 - In the process of obtaining quotes.
Lighting Upgrade	Obtain quotes for replacing all exsisting non LED light fittings with low energy LED substitutes	Yes	08/10/2024	CRJ Electricals confirmed all light fittings in the Town Council Building are LED.
Draft Proofing	Replace damaged extraction fan vent x 2	Yes	10/10/2024	Damaged vents replaced by CRJ Electricals.
MID TERM				
Increasing Installation	Quote to install extra insulation in the loft to create an overall depth of 300mm.	Yes	28/10/2024	Independent Energy Savers UK Ltd undertook a full investigation of the loft, and confirmed that the existing loft insulation fully meets the current recommendations/requirements (depth of 300mm), and therefore no additional insulation is required.
Air Source Heat Pump	Obtain quotes to replace existing gas boiler with a Air Source Pump system			
Air Source Heat Pump	Explore possible grant funding for a ASHP/Battery Storage			
LONG TERM				
Renewables and Storage	Battery storage			Energy Auditor has advised that there is no benefit/justification battery storage, unless/until an Air Source HeaT Pump is installed.
Air Source Heat Pump	Explore possible grant funding for a ASHP with battery storage			